



OWNER'S MANUAL



KCCHT-06 MODBUS



Thank you very much for purchasing our product.

Before using your unit, please read this manual carefully and keep it for future reference.

- This manual gives detailed description of the precautions that should be brought to your attention during operation.
- In order to ensure correct service of the wire controller please read this manual carefully before using the unit.
- For convenience of future reference, keep this manual after reading it.

Restore initialization

If the user accidentally sets the display language of the wire controller to a language that the user does not know, the following three steps can be used to restore the wire controller to the factory setting and reset the display language:

1) Power off the wireline controller and power it on again. Press and hold \ominus + \rightarrow + \bigcirc to enter the following page within 60 seconds.



2) Press the buttons from left to right, from top to bottom, click $\ominus -> \blacktriangle -> \bigcup ->...$ Turn on 1, 2, 3, 4, 5, 6, 7, 8 and 9, wait for 100% initialization, and enter the FCT page. After entering the FCT page, the version number is displayed. All set parameters of the equipment are reset to the default parameters, and saved. The timing settings and fault records are cleared. The equipment returns to the factory state. (exit FCT after power on again).

3) Power off the wireline controller and power it on again. The display language will be reset. Press " ▲ " " ♥ " " ◀ " " ▶ " to select the language of the remote controller. After the language setting is completed, click " ← ", select "YES", and then click " ← " to enter the SETTING ADDRESS interface. After setting SETTING ADDRESS, click " ← " to enter GENERAL SETTING. Then after setting GENERAL SETTING, click " ← ".

Contents

1 Safety Precautions	1
2 Overview of Wired Controller	3
3 Function Introduction	8
4 Attached Table 1: Outdoor unit errors and protection codes	
5 Attached Table About Modbus	42

1 Safety Precautions

The product and Operation and Installation Instructions record the following content, including the operation method, how to prevent harms to others and property losses, and how to use the product correctly and safely. Read the text after understanding the content (identification and marker maps) below carefully, and observe the precautions below.

▲ Caution

Read the safety precautions carefully prior to installation. The important safety precautions are provided below and must be observed. Meanings of marks:

▲ Caution Means improper handling may lead to personal injuries or material damages.

▲ Warning Means improper handling may lead to death or serious injury. After the installation work is completed, confirm that the trial operation is normal and hand over the manual to the customer for keeping.

[Note]: So-called "injuries" mean the harms not requiring hospitalization or long-term treatment, generally referring to wounds, burns, or electric shocks. Material damages refer to property and material losses.

1 Safety Precautions

Icon	Name			
\otimes	It indicates "prohibited". The specific content of prohibition is provided using graphics or text in the icon or nearby.			
(!)	It indicates "mandatory". The specific mandatory content is provided using graphics or text in the icon or nearby.			
A Entrusted installation Entrust your distributor or a prof product. The installation operator relevant professional knowledge In case of independent installatil lead to a fire, electric shock, or i		Entrusted installation	Entrust your distributor or a professional to install the product. The installation operator must have acquired the relevant professional knowledge. In case of independent installation, wrong operations will lead to a fire, electric shock, or injury.	
Prohibited		Prohibited	Do not spray combustible spray to the wired controller directly; otherwise a fire may be caused.	
Caution in Use		Prohibited	Do not perform operations with a wet hand or allow water to enter the wired controller; otherwise the wired controller will be damaged.	

▲ Caution

• Do not install the product at a place where flammable gas easily leaks. Once flammable gas leaks and stays around the wired controller, a fire may be caused.

2 Overview of Wired Controller

Basic using conditions:

1)Power range: power input: AC 8V ~ 12V;

2)Operating temperature: -20°C~60°C;

Operating humidity: RH40%~RH90%;

Where: HP-HEAT PUMP;CO-ONLY COOLING;FC-FREE COOLING.

It's a general manual. The functions of different models are different. The wired controller automatically recognizes and hides irrelevant interfaces. Please set and inquire related parameters according to the outunit model.

2.1 Operation Interface Description



2 Overview of Wired Controller



Set temperature:TWS/T5S:SETTING TEMPERATURE;TW:TOTAL OUTLET WATER TEMPERATURE, T5:TANK TEMPERATURE;TSF:SAFE TEMPERATURE;



3 Function Introduction

3.1 Unlocking/Locking Operation

When the wired controller is locked, press and hold the " a " button for 3s to unlock it. Then the lock icon is not displayed and the wired controller can be operated.

When the wired controller is unlocked. press and hold the " a " button for 3s to unlock it. Then the lock icon is displayed and the wired controller cannot be operated. When there is no operation for continuous 60s on any page, the wired controller returns to the home page and automatically locks, displaying the lock icon.

Note: It can only be locked by long pressing the " a " button for 3s under the main page, and it is invalid under the ") " page.

12/04/2019 MON 10:35A	12/04/2019 MON 10:35A
$\begin{array}{c c} \hline \begin{array}{c} & & & \\ \hline \hline$	

3.2 Power-on/off

When the wired controller is unlocked and the unit is on, "U" can be pressed to power off the unit under the home page only. And it can be pressed to power on the unit when the unit is off.

In the unlocked state, the set temperature can be adjusted by pressing $\blacktriangle \forall$ button. And you need to Press " \longleftarrow "button to confirm after setting. It's invalid without confirmation within 5s.

	LOCK	UNLOCK: ON	UNLOCK: OFF
HP-COOLING	12/04/2019 MON 10:35A → TWS TW 9 °C COOL 7 °C ON I ↔ 45% 0.60% +	1204/2019 MON 10:35A → TWS TW 9 °C COOL 1 7 °C ON 1 ONLINE 16 45% € 80% ↓	1204/2019 MON 10:35A
CO-COOLING	1204/2019 MON 10:35A B₩E 	12/04/2019 MON 10:35A 3₩E \$\$\$ \$\$\$ \$\$\$ \$\$\$ \$\$\$ \$\$\$ \$\$\$ \$	12/04/2019 MON 10:35A
FC-COOLING		толиота мон то зада — — — — — — — — — — — — — — — — — —	1204-0219 MON 10 28A
HP-HEATING	12/04/2019 MON 10:35A ★ TWS TW 40°C HEAT 55 °C ONLINE 16 ON & 45% 0 80% 00	12/04/2019 MON 10:35A	12/04/2019 MON 10:35A * TWS TW 40°C HEAT 55 °C ONLINE 16
HP-HOTWATER	12/04/2019 MON 10:35A Image: State S	12/04/2019 MON 10:35A T 55 T5 40 °C DHW 60 °C ONLINE 16 ON 45% 0 80% 39	12/04/2019 MON 10:35A → T55 T5 40 °C DHW 60 °C ONLINE 16 45% € 80% &

3.3 Mode Setting

In Unlock mode, Press " \square " button to enter the menu setting interface, Press " \checkmark " and " \blacktriangle " buttons to select "MODE" and set a mode, and Press " \leftarrow " button as shown in the above figure to access the submenu (mode setting). As shown below: three modes available.



Cycle: Cooling-->Heating-->DHW-->Cooling. Skip the mode cycle when there is no corresponding mode. The DHW mode is divided into single pump (no need to select the address) and multiple pumps (need to select address 00-15, and the address of the unit without DHW function is directly skipped).

Only Tws/T5s and address can be set in cooling, heating and DHW mode. Tw/T5 can only be displayed but not be set. DHW can only be power on/off under the MODE setting.

HP-Cooling setting range lower limit is subject to the low water outlet control setting under SERVICE MENU. CO/FC-Cooling setting range lower limit is subject to the lowest outlet water temperature set by antifreeze ratio under PROJECT MENU.

Note: When the setting temperature is lower than 5°C, the water-side system must increase more than 15% of antifreeze, otherwise there will be a risk of damage to the unit.

Press " \checkmark " to save the settings after setting and back to homepage. Or press" " to back. When there is no operation for continuous 60s, it will save the settings and back to homepage.

3.4 Menu Setting



Ν	NODE (DISABLE)	
	USER MENU	
:	SERVICE MENU	
F	PROJECT MENU	
OK		¢

The default selection is "MODE" and choose the menu you need by pressing " \blacktriangle ". Press " \twoheadleftarrow " to enter its submenu or back to homeage by " \bigcirc ". Back to homepage if there is no operation for 60s under menu page.

Note: the mode menu is invalid when the unit is controlled by modbus or host computer and display as above.

4.3.6.1 USER MENU

Select "USER MENU" to enter the user menu. The interface display is as follows:

USER MENU	
QUERY	
TIMER	
GENERAL SETTING	
DOUBLE SETPOINT	
OK 1/2	÷

USER MENU
SNOW-BLOWING SWITCH
SILENT SWITCH
DHW SWITCH
ОК 2/2 🗘

Users choose functions by " ▲ ▼ ".

Select "QUERY" in the "USER MENU" interface to access the query function. The interface display and operation are as follows:

QUERY	
STATE QUERY	
TEMP QUERY	
HISTORY ERRORS QUERY	
OK	41

State query

Select "STATE QUERY" and press " - ". Display as follows:

STATE QUERY	
SELECT ADDESS	I1 ▶ #
OPERATION STATE	STANDBY
RUNNING MODE	COOL
CURREN SLIENT	NIGHT
MODE	SILENT1
BACK	0

Select address by pressing " \triangleleft ", " \blacktriangleright " to view the status of the unit at that address. Back to upper menu by " \preceq ".

Temp query Select "TEMP QUERY" and press " - ". Display as follows:

TEMP QUERY			
SELECT ADDESS	۰	11	#
INLET WATER TEMP		25	°C
OUTLET WATER TEMP		25	°C
TOTAL OUTWATER TEMP		25	°C
AMBIENT TEMP		25	°C
BACK			4

Select address by pressing " ◀ ", " ► " to view the temperature of the unit at that address. Back to upper menu by " ".



Select address by pressing " \blacktriangleleft ", " \blacktriangleright " to view the history errors of the unit at that address. Press " \blacktriangle " " \checkmark " to choose the history error that you want and the number of errors that can be viewed is 16. Timer setting

Select "TIMER" and press " - ". Display as follows:

TIMER	TIMER
DAILY TIMER	DAILY TIMER(DISABLE)
WEEKLY SCHEDULE	WEEKLY SCHEDULE(DISABLE)
ОК 🗘	ок

Note: After MODBUS control and the remote control of the external machine are used, the daily and weekly time settings of the wired controller are invalid, and users cannot enter the timing menu for setting.

When MODBUS control and the remote control of the external machine are invalid. Select "DAILY TIMER" and press " - ". Display as follows:

DAILY TIMER	
TIMER	I ► #
ACT	4 0FF ▶
TIME ON	◀ 10:00 ► A
TIME OFF	▲ 10:00 ► A
MODE	IN HEAT ►
OK 1/2	+

DAILY TIMER	
TWS	 40 ▶ °C
SILENT MODE	 NIGHT ►
	SILENT1
OK 2/	2

Only one setting is enabled between "DAILY TIMER" and "WEEKLY SCHEDULE". If any of the pattern in "WEEKLY SCHEDULE" is set to ON, "DAILY TIMER" is disabled. "DAILY TIMER" can be set across days, but "WEEKLY SCHEDULE" can't.

Users can set up to two timers, and set the ON or OFF time (set the interval of time to 10 minutes), operation mode(there are heating, cooling and DHW modes for single pump; only cooling and heating modes can be selected for multiple pumps, and it cannot be set as DHW mode) and temperature setting for each segment of timer.

It's invalid if the ON and OFF time are same. Display as follows:



Operating Introduction:

Press " ▲ " " ▼ " to select TIMER, ACT, TIME ON, TIME OFF, MODE, TWS or SILENT MODE. When the cursor stays at "TIMER ", press " ◀ " and " ▶ " to select "TIMER 1" or "TIMER 2". When it stays at other items, we can also use " ◀ ", " ▶ " to adjust corresponding settings.

After setting, press " \rightarrow " to confirm saving, or press " \rightarrow " to cancel setting and return to the previous interface.

If Time1 T.ON is set the same as Time1 T.OFF, then the setting is invalid, the ACT option for the timer of this segment jumps to "OFF", the setting of Timer2 is the same as that of Time1, and the timing interval of Time2 can cross with that of Time1.

For example, if Timer1 T.ON is set to 12:00 and Timer1 T.OFF is set to 15:00, then the values of Timer2 T.ON and Time2 T.OFF can be set in the range of 12:00-15:00. If the time interval crosses, the machine will be powered on at the time T.ON which is set in Timer1 or Timer2, and will be powered off at the time T.OFF which is set in Timer1 or Timer2.

After the daily timer function setting is enabled, there will be corresponding prompts displayed on the homepage.

When two timers overlap, the second setting takes precedence.

Weekly schedule setting:

Select "WEEKLY SCHEDULE" and press " Lisplay as follows:

WEEKLY SCHEDULE		
WEEKLY SCHEDULE	MON ►	
WEEKLY SWITCH	◆ OFF ▶	
OK		

MONDAY TIMER	
TIMER	▲ 1 ▶ #
ACT	4 0FF ▶
TIME ON	◀ 10:00 ► A
TIME OFF	▲ 10:00 ► A
MODE	IN HEAT ►
OK 1/2	\$ ↔

MONDAY TIMER	
TWS	 40 ▶ °C
SILENT MODE	 NIGHT ►
	SILENT1
OK 2/2	\$ ₽

Press " ▲ " and " ▼ " buttons to select "WEEKLY SCHEDULE" or "WEEKLY SWITCH". And press " ◀ " or " ▶ " buttons to select Monday to Sunday.

There can be up to 2 timings in a day of weekly timing, and each timing needs to be set on and off time (set interval is 10 minutes).

Operating Introduction:

Press " ▲ " and " ▼ " to select "WEEKLY SCHEDULE". Select the day you need by " < " or " ▶ ", and press " ← J " to enter it. Then you can switch between TIMER, ACT, TIME ON, TIME OFF, MODE, TWS and SILENT MODE by " ▲ " and " ▼ ". Refer to the operating introduction of "DAILY TIMER".

General setting:

Select "GENERAL SETTING" and press " - Display as follows:

GENERAL SETTING			
YEAR	٩	2020	•
MONTH	٠	12	Þ
DAY	٠	10	•
12-24HOUR	٠	12	•
HOUR	٠	10	•
OK 1/2			÷ •

GENERAL SETTING			
MINUTE	4	55	Þ
AMPM	4	AM	Þ
LANGUAGE	٩E	NGLIS	H►
BACKLIGHT	٠	20	+
OFF DELAY(s)			
OK 2/2		\$	•

Press " \blacktriangle " and " \checkmark " to select the date, time, and time format to be set. Adjust their parameters by " \blacktriangleleft " or " \triangleright ", and press " \checkmark " to save. The backlight time setting range is 10-1200s, the default is 60s, and each adjustment is 10s.

Back to previous page by " 🖄 " after setting. Only English is supported now. Double Setpoint

Select "DOUBLE SETPOINT" and press " 🚽 ". Display as follows:

DOUBLE SETPOINT			
DOUBLE SETPOINT	4[DISAE	BLE 🕨
SETPOINT COOL_1	4	16	°C
SETPOINT COOL_2	4	20	▶ °C
SETPOINT HEAT_1	4	16	
SETPOINT HEAT_2	4	25	▶ °C
OK			÷ •

Press " ▲ " and " ▼ " to select items and " ◄ " or " ► " to adjust parameters.

the lower limit of the set range of HP refrigeration is subject to the low water outlet control set under SERVICE MENU, and the lower limit set for CO/FC refrigeration is subject to the minimum water outlet set under the antifreeze ratio set under PROJECT MENU.

Snow-Blowing switch

OK	
SNOW-BLOWING SWITCH YES 🗘	
SNOW-BLOWING SWITCH	

Press " ▲ " and " ▼ " to select "YES" or "NO" and press " ← " to confirm. "YES" means the function is valid, "NO" means invalid.

Note:Some models do not have this function. Please refer to the instructions of the outdoor machine for whether they have anti-snow control function. Silent mode:

Select "SILENT SWITCH" and press "

SILENT SWITCH	
SELECT SILENT	 NIGHT ► SILENT1
CURRENT SILENT	NIGHT SILENT1
ок	¢

Press "▲ " and "▼ " to select "SELECT SILENT", press" ◀ " or " ▶ " to select the mode you need (7 types: NIGHT SILENT1-4, STANDARD, SILENT and SUPER SILENT), and press "↓" to save. Users can check whether it is the mode they want here and press " ↓" to back if there is no problem. Once the silent mode turned on, in homepage light up.

NIGHT SILENT 1	6/10h
NIGHT SILENT 2	6/12h
NIGHT SILENT 3	8/10h
NIGHT SILENT 4	8/12h

Note: Night Silent1-4 is only available for MC-SU **-RN8L-B series models.

DHW SWITCH

Press " ▲ " and " ▼ " to select "DHW SWITCH" under "USER MENU" page and press "↓

DWH SWITCH			
SELECT ADDESS	٩	11	• #
DWH SWITCH	4	YES	•
DHW FIRST	٩	YES	•
00 01 02 03 04	05	06	07
08 09 10 11 12	13	14	15
ОК		E	•

Press " ▲ " and " ▼ " to switch between SELECT ADDRESS, DHW SWITCH and DHW FIRST. Then press" ◀ " or " ▶ " to adjust parameters.

Only when DHW SWITCH selects YES, the following can be set.

Note: DHW SWITCH is only available for custom made DHW models.

Water Coil Control

Press " \blacktriangle " and " \blacktriangledown " to select "WATER COIL CONTROL" and press " $\blacklozenge l$ ". Display as follows:

WATER COIL CONTROL			
COIL CONTROL	COIL CONTROL AUTO		
OK 🔸			

Press "▲ " and " ▼ " to select "COIL CONTROL" and press " ◀ " or " ▶ " to select control mode: AUTO (automatically control), MANUALON (with water coil), MANUALOFF (without water coil). Press " ← J " to save. Press " ← J " to exit this page. Note: Water Coil Control is only applicable to FC models.

4.3.6.2 SERVICE MENU SETTING

Password input: Please contact us

Select "SERVICE MENU" and press " - The screen prompts for a password, as shown in the figure below:

SERVICE MENU	
PLEASE INPUT THE PASSWORD	
000	
ОК	\$ ₽

Display as follows if the input is incorrect:



Enter setting page as follows if the input is correct:

SERVICE MENU	
STATE QUERY	
CLEAR HISTORY	ERRORS
SETTING ADDRE	SS
HEAT CONTROL	
OK 1/3	

SERVICE MENU
TMEPERATURE COMPENSATION
PUMP CONTROL
MANUAL DEFROST
LOW OUTLET WATER CONTROL
ОК 2/3

SERVICE	MENU	
VACUUM	SWITCH	
ENERGY	SAVING SWITCH	
DHW ENA	ABLE	
FACTORY	DATA RESET	
OK	3/3	÷

State query

Press "▲ " or "▼ " to select "STATE QUERY" under "SERVICE MENU" page. Then press " ▲ " to enter submenu.

STATE QUERY			
SELECT ADDRESS	۰	07	• #
ODU MODEL		130	kW
COMP FREQUENCE		50	Hz
COMP1 CURRENT		20	Α
COMP2 CURRENT		20	Α
BACK		E	•

STATE QUERY		
H-P PRESSURE	3.83	MPa
L-P PRESSURE	1.00	MPa
TP1 DISCHARGE TEMP	30	°C
TP2 DISCHARGE TEMP	30	°C
TH SUCTION TEMP	-20	°C
OK 2/9		ŧ

STATE QUERY	
TZ TEMP	-20°C
T3 TEMP	-20°C
T4 TEMP	-20°C
T6A TEMP	40°C
T6B TEMP	40°C
BACK 3/9	¢

STATE QUERY		
TFIN1 TEMP	60	°C
TFIN2 TEMP	60	°C
TDSH	30	°C
TSSH	15	°C
TCSH	15	°C
BACK 4/9		40

STATE QUERY	
FAN1 SPEED	850 RPM
FAN2 SPEED	850 RPM
FAN3 SPEED	850 RPM
EXV A	1800 P
EXV B	1800 P
BACK 5/9	ŧ

STATE QUERY		
EXV C		1800P
Twi TEMP		30°C
Two TEMP		30°C
Tw TEMP		30°C
TAF1 TEMP		30°C
BACK	6/9	¢

STATE QUERY			
TAF2 TEMP		30 °	С
T5 TEMP		30 °	С
COMP TIME1		120 M	IN
COMP TIME2		120 M	IN
COMP TIME3		120 M	IN
BACK	7/9	I	ŧ

STATE QUERY	
COMP TIME	65535 H
FIX PUMP TIME	65535 H
INV PUMP TIME	65535 H
ODU SOFTWARE	V45
HMI SOFTWARE	V45
BACK	/9

STATE QUE	RY	
DEFROSTIN	NG STATE	
00 01 02	2 03 04 05	06 07
08 09 10	11 12 13	14 15
E2 SOFTWA	ARE V45	
END		
OK	9/9	\$ Φ

Press " ◀ " or " ▶ " to select the address of module to view (the offline address is skipped automatically). There are 9 pages and 41 state values. Press " ▲ " or " ▼ " buttons to select the different page.

Clear history errors:

Press " ▲ " or " ▼ " to select "CLEAR HISTORY ERRORS" and confirm by " ↓ ".





Press " ▲ " or " ▼ " to select "CLEAR UNIT HISTORY ERRORS" and press " ← " to confirm. Display as follows:

CLEAR UNIT HIS ERRS	
SELECT ADDRESS	● 07 ▶
DO YOU WANT TO	▲ YES ▶
CLEAR?	
OK	÷ ⊕

Press" ▲ " or " ▼ " to select "SELECT ADDRESS" and press " ◀ " or " ► " to select address value. Press " ▲ " or " ▼ " to select clear or not, and press " ◀ " or " ► " to select YES or NO, and press " ◀ " in to confirm.

Press" ▲ " or " ▼ " to select "CLEAR ALL HIS ERRS" and press " ← I " to confirm. Display as follows:

CLEAR ALL HIS ERRS		
DO YOU WANT TO CLEAR?	 YES ▶ 	
ОК		

Press" \blacktriangle " or " \triangledown " to select "CLEAR LOCK ERROR" and press " \longleftarrow " to confirm. Display as follows:



press " ◀ " or " ► " to select YES or NO, and press " ◀ " to confirm.

Press" ▲ " or " ▼ " to select "CLEAR RUN TIME" and press " ← I " to confirm. Display as follows:

CLEAR RUN TIME	
SELECT ADDRESS	▲ 07 ▶
CLEAR COMP TIME?	INO ►
CLEAR FIX PUMP TIME?	▲ NO ▶
CLEAR INV PUMP TIME?	NO ▶
OK 🗘 🕈	

Press " ▲ " or " ▼ " to select "SELECT ADDRESS", press " ◀ " or " ► " to select address value.

Press " ▲ " or " ▼ " to select clear or not, and press " ◀ " or " ► " to select YES or NO, and press " ◀ " it to confirm.

Setting address :

Press " ▲ " or " ▼ " under "SERVICE MENU" page to select "SETTING ADDRESS" (Can also enter by combining buttons pressing " 🖨 ", " ► " for 3s). Press " ← I " and enter submenu.

SERVICE M	ENU
STATE QUE	RY
CLEAR HIST	FORY ERROR
SETTING AD	DDRESS
HEAT CON	TROL
OK	1/3

SETTING ADDRESS			
CONTROLLER ADDRESS	•	10	▶ #
CONTROL ENABEL	٠	NO	•
MODBUS ENABLE	٠	NO	•
MODBUS ADDRESS	4	10	▶ #
OK		I	\$ ↔

Press " ▲ " or " ▼ " to select item and press " ◀ " or " ► " to set value. Then press " ←] " to confirm and ") " to back.

Heat control

HEAT1 means pipe electric heating in cooling/heating mode. HEAT2 means tank electric heating in DHW mode.

Press "▲ " or "▼ " to select "HEAT CONTROL" under "SERVICE MENU" page. Press " ← I " and enter submenu.

SERVICE MENU	HEAT CONTROL
STATE QUERY	HEAT1
CLEAR HISTORY ERROR	HEAT2
SETTING ADDRESS	FORCED HEAT2 OPEN
HEAT CONTROL	TOROED TIEATZ OF EN
OK 1/3 🗘	OK ₽

Press " ▲ " or " ▼ " to select item to be set. Press " ← I and enter submenu.

HEAT1			
HEAT1 ENABLE	٠	NO	•
TEMP-	٠	07	▶°C
AUXHEAT1-ON			
TW.HEAT1-ON	٠	25	▶°C
TW.HEAT1-OFF	٠	45	▶°C
OK 1/2			\$ 4>

HEAT2			
ALL HEAT2 DISABLE	٠	YES	•
SELECT ADDRESS	٠	10	▶ #
HEAT2-ENABLE		NO	•
T-HEAT2-DELAY		190	► MIN
DT5-HEAT2-OFF		10	▶°C
OK 1/2			\$ ●





Press " ▲ " or " ▼ " to select item and press " ◀ " or " ► " to set value. Then press " ← " to confirm and ") " to back.

Temperature Compensation:

Press "▲ " or " ▼ " to select "TEMPERATURE COMPENSATION" under "SERVICE MENU" page. Press " ← I" and enter submenu.

SEDVICE MENU	TEMP COMPENSATI	TEMP COM	
	COOL MODE ENABLE	 YES ▶°C 	HEAT MODE E
IMEPERATURE COMPENSATION	T4 COOL-1	 15 ▶°C 	T4 HEAT-1
PUMP CONTROL	T4 COOL-2	 4 08 ▶°C 	T4 HEAT-2
MANUAL DEFROST	OFFSET-C	I0 ▶°C	OFFSET-H
LOW OUTLET WATER CONTROL			
OK 2/3	OK 1/2	\$ Φ	ОК

TEMP COMPENSATION			
HEAT MODE ENABLE	٠	YES	▶°C
T4 HEAT-1	٠	15	►°C
T4 HEAT-2	٠	08	▶°C
OFFSET-H	٠	10	• °C
OK 2/2			\$ ₽

Press " ▲ " or " ▼ " to select item and press " ◀ " or " ► " to set value. Then press " ← " to confirm.

Pump Control:

Press " ▲ " or " ▼ " to select "PUMP CONTROL" under "SERVICE MENU" page. Press " ↓ " and enter submenu.

SERVICE MENU	PUMP CONTROL
TMEPERATURE COMPENSATION	FORCED PUMP OPEN
PUMP CONTROL	INV PUMP SETTING
MANUAL DEFROST	PUMP ON/OFF TIME
LOW OUTLET WATER CONTROL	
OK 2/3	OK 😫

Press " ▲ " or " ▼ to select "FORCED PUMP OPEN" . Press " ← " and enter submenu.

FOECED PUMP OPEN			
SELECT ADDRESS	٩	0	• #
FORCED PUMP OPEN	٠	NO	•
OK		40	÷

FORCED PUMP OPEN	
Cannot control the pump before shutting down.	

Under "FORCED PUMP OPEN" page, press " ▲ " or " ▼ " to select item and press " ◀ " or " ▶ " to set value. Press " ← " to confirm or " ´) " to back. If the unit at that address is ON, the pump cannot be controlled by the wired controlled. Display as above. Under "INV PUMP OPEN" page, press " ▲ " or " ▼ " to select item and press " ◀ " or " ▶ " to set value. Press " ← " to confirm or " ◯ " to back.

INV PUMP SETTING	
SELECT ADDRESS	4 07 ▶ #
SWITCH ON THE PUMP	 NO ▶
RATIO PUMP	100 ▶ #
OK	<₽ \$

Note: Can only be set under a single pump ,The setting range of RATIO-PUMP is 30%-100%. It should ensure its flow meet the requirement of whole unit, otherwise the unit may be damaged.

Under "PUMP CONTROL" page, press " ▲ " or " ▼ " to select item and press " ◀ " or " ► " to set value. Press " ◀ " to confirm or " 勹 " to back.

PUMP ON/OFF TIME	
PUMP ON TIME	4 05 ► MIN
PUMP OFF TIME	4 05 ► MIN
OK	<₽ \$

Parameter setting requirements are as follows:

	Set range	Default value	Adjustment range
PUMP ON TIME	5~60min	5	5
PUMP OFF TIME	0~60min	0	5

Manual Defrost

Press " ▲ " or " ▼ " to select "MANUAL DEFROST" under "SERVICE MENU" page. Press " ↓ " and enter submenu.

SERVICE MENU	MANUAL DEFROST	
TMEPERATURE COMPENSATION	SELECT ADDRESS 4 0	7 • #
PUMP CONTROL	MANUAL DEFRIOST 4 N	10 •
MANUAL DEFROST		
LOW OUTLET WATER CONTROL		
OK 2/3	OK	< +

Press " ▲ " or " ▼ " to select item to be set and press " ◀ " or " ▶ " to set value. Press " ◀ " to confirm or " ጏ " to back.

If the external unit successfully enters the defrost mode after the "MANUAL DEFROST" is turned on, the defrost icon will be displayed at homepage of the wired controller.

Low outlet water temperature control

Press " ▲ " or " ▼ " to select "LOW OUTLETWATER CONTROL" under "SERVICE MENU" page. Press " ← " and enter submenu. Suitable for HP-UNIT.

SERVICE MENU
TMEPERATURE COMPENSATION
PUMP CONTROL
MANUAL DEFROST
LOW OUTLET WATER CONTROL
OK 2/3

LOW OUTLET WATER CTRL		
MIN TEMP FOR COOL	 4 50°C ► 	
HISTORICAL SETTING		
04/06/2020 11:30A	5°C	
04/06/2020 11:30A	5°C	
04/06/2020 11:30A	5°C	
ОК	ŧ	

Press " ◀ " or " ▶ " to set value. Press " ↓ " to confirm or ") " to back. At this page, the historical minimum water outlet temperature setting (setting range 0-20°C) can be viewed. When the setting temperature is less than 5°C, a prompt box will pop up:



Note: Only applicable to MC-SU **-RN8L-B series models. For other models, please refer to the instructions of the outdoor machine.

Vacuum mode

Press "▲ " or "▼ " to select "VACUUM SWITCH" under "SERVICE MENU" page. Press " ← " and enter submenu.

SERVICE N	IENU	
VACUUM S	WITCH	
ENERGY S	AVING SWITCH	
DHW ENAE	BLE	
FACTORY I	DATA RESET	
OK	3/3	¢

VACUUM SWITCH		
VACUUM SWITCH	 NO 	
OK 🗧		

Press " ◀ " or " ► " to set YES or NO. Then press " ← " to confirm. Power off and restart is required to exit it.

Note: Only applicable to MC-SU **-RN8L-B series models.For other models, please refer to the instructions of the outdoor machine. Energy saving mode

Press " ▲ " or " ▼ " to select "ENERGY SAVING SWITCH" under "SERVICE MENU" page. Press " ← I" and enter submenu.

PUMP OFF TIME PUMP DOWN TIME 0 \circ 60min

SERVICE	MENU	
VACUUM	SWITCH	
ENERGY	SAVING SWITCH	
DHW ENA	BLE	
FACTORY	DATA RESET	
OK	3/3	ŧ

ENERGY SAVING SWITCH		
SAVING SWITCH	4 80% ►	
HISTORICAL SETTING		
04/06/2020 11:30A	80%	
04/06/2020 11:30A	80%	
04/06/2020 11:30A	80%	
OK	ŧ	

press " ◀ " or " ► " to set value. Press " ◀ " to confirm or ")" to back.

Note: Only applicable to MC-SU **-RN8L-B series models.For other models, please refer to the instructions of the outdoor machine.

DHW ENABLE

Press " ▲ " or " ▼ " to select "DHW ENABLE" under "SERVICE MENU" page. Press " ← " and enter submenu.

DHW ENABLE	
DHW ENABLE	NO ▶
OK	₽

Press "▲ " or "▼ " to set YES or NO. Press " ← " to confirm or " [^] to back. Note: DHW ENABLE is only available for custom made DHW models.

Factory data reset:

Press " ▲ " or " ▼ " to select "FACTORY DATA RESET" under "SERVICE MENU" page. Press " ← I" and enter submenu.

FACTORY DATA RESET		
DO YOU WANT TO RESET?	 YES ▶ 	
OK	•	

Press " ▲ " or " ▼ " to select corresponding item and press " ◀ " or " ► " to select restore or not. Press " ← " to confirm or " [^]) to back.

4.3.6.3 PROJECT MENU SETTING

Password input: Please contact us.

Select "PROJECT MENU" and press "
 " to entry. The screen prompts to enter the password, as shown in the figure below:



The initial password must be obtained by a professional. Press the " \blacktriangle " or " \lor " buttons to change the number to enter, and press the " \lt " or " \succ " buttons to change the bit code to enter. After the number is entered, the display is not changed. After entering the password, press the " \lrcorner " button to enter the interface; press the " \bigcirc " button to go back to the previous interface; the display is as follows if the input is incorrect:

PROJECT MENU
SORRY WRONG PASSWORD PLEASE INPUT AGAIN
0000
ОК 🗘 🕈

The query interface as follows is displayed if the input is correct:

PROJECT MENU	
SET UNIT AIRCONE	DITIONING
SET PARALLEL UN	Т
SET UNIT PROTEC	TION
SET DEFROSTING	
OK 1/3	¢

PROJECT MENU
SET DHW TIME
SET E9 TIME
INV PUMP RATIO
CHECK PARTS
OK 2/3

PROJECT	MENU	
PERCENT	OF GLYCOL	
WATER CO	DIL CONTROL	
OK	3/3	¢

Unit Setting:

Select "SET UNIT AIRCONDITIONING" and press " - " to entry. Display as follow:

SET UNIT			
TWO_COOL_DIFF	٩	2	● °C
TWO_HEAT_DIFF	٠	2	♦ °C
DT5_ON	٠	8	°C
DTIS5	٠	10	°C
DtTws	٠	1	▶°C
ОК			<₽ ♦

SET UNIT			
Dtmix	4	2	► °C
FCoffset	٩	2	♦ °C
FChyser	٠	1	♦ °C
ОК			\$ ••

ŧ

Press " ▲ " or " ▼ " to select item and press " ◀ " or " ▶ " to set suitable temperature or time. Press " ◀ " to confirm. Back to homepage if there is no operation within 60s. Detailed setup information:

Parameter	Setting range	Note
Two_COOL_DIFF	1 ∽ 5°C	
Two_HEAT_DIFF	1 ∽ 5°C	
dT5_ON	2 ∽ 10°C	
Dt1s5	5 ∽ 20°C	DHM

Parallel units setting:

Select "SET PARALLEL UNIT" and press " 🛶 " to entry. Display as follows:

SET PAPALLEL UNIT			
TIM_CAP_ADJ	٩	180	۰S
TW_COOL_DIFF	٠	2	▶ °C
TW_HEAT_DIFF	۰	2	▶ °C
RATIO_COOL_FIRST	۲	0	۰%
RATIO_HEAT_FIRST	٠	50	• %
ОК			\$ ₽

Press " ▲ " or " ▼ " to select item to be set and press " ◀ " or " ▶ " to set value. Press " ◀ " to confirm. Back to homepage if there is no operation within 60s.

Detailed setup information:

Parameter	Setting range
Tim_Cap_Adj	60s ∽ 360s
Tw_Cool_diff	1 ∽ 5°C
Tw_Heat_diff	1 ∽ 5°C
Ratio_cool_first	5 ∽ 100%
Ratio_heat_first	5 ∽ 100%

Unit protection setting:

Select "SET UNIT PROTECTION" and press " - " to entry. Display as follows:

SET UNIT PROTECTION			
T_DIFF_PRO	٠	12	▶ °C
TWI_O ABNORMAL	٠	2	▶ °C
OK 🗘 🕈			

30

Press " ▲ " or " ▼ " to select item to be set and press " ◀ " or " ▶ " to set value. Press " ← " to confirm. Back to homepage if there is no operation within 60s. Detailed setup information:

Parameter	Setting range
T_DIFF_PRO	8 ∽ 15°C
T_DIFF_PRO	1 ∽ 5°C

Defrosting Setting:

Select "SET DEFROSTING" and press " 🚽 " to entry. Display as follows:

SET DEFROSTING			
T_FROST	٠	35	▶ min
T_DEFROST_IN	٩	0	• °C
T_FROST_OUT	٠	0	♦ °C
OK			\$ ₽

Press " ▲ " or " ▼ " to select item to be set and press " ◀ " or " ► " to set value. Press " ↓ " to confirm. Back to homepage if there is no operation within 60s. Detailed setup information:

Parameter	Setting range
T_FROST	20 ∽ 120min
T_DEFROST_IN	-5 ∽ 5°C
T_FROST_OUT	-10 ∽ 10°C

DHW time setting:

Select "SET DHW TIME" and press " - " to entry. Display as follows:

SET DHW TIME			
SELECTADDRESS	٠	07	• #
COOL MAX TIME	٠	08	►h
COOL MIN TIME	٠	0.5	۰h
HEAT MAX TIME	•	08	► h
HEAT MIN TIME	٠	0.5	۱
OK 1/2			¢ 🔹

SET DHW TIME			
DHW MIN TIME	٠	0.5	►h
DHW MAX TIME	٠	08	►h
OK 2/2			\$ ••

Press " ▲ " or " ▼ " to select item to be set and press " ◀ " or " ▶ " to set value. Press " ↓ " to confirm. Back to homepage if there is no operation within 60s. Detailed setup information:

Parameter	Setting range
SELECT ADDRESS	0 ∽ 15
COOL MIN TIME	0.5~24h
COOL MAX TIME	0.5~24h
HEAT MIN TIME	0.5~24h
HEAT MAX TIME	0.5~24h
DHW MIN TIME	0.5~24h
DHW MAX TIME	0.5~24h

E9 Error time setting:

Select "SET E9 TIME" and press " - " to entry. Display as follows:

	_		
SET E9 TIME			
E9 PROTECT TIME	٠	10	۰S
E9 DETECTION METHOD	٠	1	▶ #

Press " \blacktriangle " or " \lor " to select item to be set and press " \blacktriangleleft " or " \triangleright " to set value (setting range 2-20s, default 5s, adjust interval 1s). Press " \blacklozenge " to confirm. Back to homepage if there is no operation within 60s. The setting range of "E9 DETECTION METHOD" is 1-2, default 1 (Method1: detect after pump starting. Method 2: detect before and after pump starting.)

Inverter pump output setting:

Select "INV PUMP RATIO" and entry the following page to select pump: Use in the case of multiple pumps, do not send instructions for single pump.

INV PUMP RATIO			
MIN RATIO	٠	70	۰%
MAX RATIO	٠	100	• %
ОК			\$ ₽

Press " \blacktriangle " or " \checkmark " to select item to be set and press" \blacktriangleleft " or " \triangleright " to set value. Press " \checkmark " to confirm. Back to homepage if there is no operation within 60s. MINRATIO setting should ensure its flow meet the requirement of the whole unit, otherwise the unit may be damaged.

MIN RATIO	MINIMUM RATIO	40 ∽ MAX RATIO
MAX RATIO	MAXIMUM RATIO	Max (70%, MIN RATIO) ∽ 100%

CHECK PARTS

Select "CHECK PARTS" and press " 🛁 " to entry submenu. Display as follows:

CHECK PARTS		CHECK PARTS		CHECK PARTS	
SELECT ADDRESS	4 07 ▶ #	SV2 STATE	OFF	SV8B STATE	OFF
FIX PUMP STATE	OFF	SV4 STATE	OFF	HEAT1 STATE	OFF
INV PUMP STATE	80%	SV5 STATE	OFF	HEAT2 STATE	OFF
FOUR-WAY VALVE	OFF	SV6 STATE	OFF	COIL VALVE	OFF
SV1 STATE	OFF	SV8A STATE	OFF		
BACK 1/3	÷ •	BACK 2/3	\$ ₽	BACK 3/3	÷ «

Press " ▲ " or " ▼ " to view 13 state. Press " ⁽) " to return to the previous page.

PERCENT OF GLYCOL

Select "PERCENT OF GLYCOL" and press " - " to entry submenu. Display as follows:

PRECENT OF GLYCOL				
GLYCOL TYPE	I ETHE ►			
SET THE PRECENT	4 70 ▶%			
TSAFE	5° C			
PAF	0.7MPa			
∆PAF	● 0 ● MPa			
BACK 1/2	\$ ₽			

PRECENT OF GLYCOL				
HISTORICAL SETTING				
04/06/2020 11:30A	80	%		
04/06/2020 11:30A	80	%		
04/06/2020 11:30A	80	%		
04/06/2020 11:30A	80	%		
OK 2/2		¢		

Press " ▲ " or " ▼ " to select item to be set and press " ◀ " or " ► " to set value. Press " ← " to confirm. Back to homepage if there is no operation within 60s. Up to 16 historical setting records.

Parameter	Setting range
GLYCOL TYPE	ETHE/PROP
SET THE PERCENT	0 ∽ 50%
TSAFE	DISPLAY
PAF	DISPLAY
△PAF	0 ∽ 0.2MPa
HISTORICAL SETTING	04/06/2020 12:00A
HISTORICAL SETTING	04/06/2020 12:00A
HISTORICAL SETTING	04/06/2020 12:00A

Water Coil Control

Press " \blacktriangle " and " \blacktriangledown " to select "WATER COIL CONTROL" and press " \blacklozenge ". Display as follows:



Press "▲ " and " ▼ " to select "COIL CONTROL" and press " ◀ " or " ▶ " to select control mode: AUTO (automatically control), MANUALON (with water coil), MANUALOFF (without water coil). Press " ← I" to save. Press " ← I" to exit this page. Note: Water Coil Control is only applicable to FC models.

4.3.7 Power Failure Memory Function

The power supply to the system fails unexpectedly during operation. When the system is powered on again, the wired controller continues to operate according to the status before the last power failure, including the power-on/off status, mode, set temperature, failure, protection, wired controller address, timer, hysteresis, etc. However, the memorized content must be the content set at least 7s before the power failure.

4.3.8 Parallel Function of Wired Controller

Parallel function by MODBUS:

1) A maximum of 16 wired controllers can be connected in parallel, and the address can be set in the range of 0 to 15.

2) After multiple wired controllers are connected in parallel, data is shared among them, e.g., the power-on/off function, data settings (such as the water temperature and hysteresis) and other parameters will be kept consistent (note: The mode, temperature, and hysteresis settings can be shared only when the system is powered on).

3) Start point of data sharing: After the power-on/off button is pressed, data can be shared during parameter adjustment. The "
 " button must be pressed after parameters are adjusted, and the finally adjusted values will be shared.

4) Since the bus is processed in the polling mode, the data of the wired controller which is set last is valid if multiple wired controllers are operated at the same time in the same bus cycle (4s). Avoid the above situation during operation.

5) After any one of parallel wired controllers has been reset, the address of this wired defaults no address and needs to be set manually in order to enter into normal communication.

Parallel function by XYE:

1) A maximum of 16 wired controllers can be connected in parallel

2) The wired controller need to set to control/monitor controller. The former has control functions, while the latter has only viewing functions.

4.3.9 Upper Computer Communication Function

1) When communicating with the upper computer, the homepage displays: Communication between the wired controller and the upper compute.

2) If the outdoor main control board is in the remote ON/OFF control mode and the wired controller icon flash. At this point, the upper computer network control setting line control mode switch machine is invalid.

4.3.10 Monitor Wired Controller Function

When the wired controller is set to monitor wired controller, press the "

CHECK MENU
QUERY
GENERAL SETTING
STATE QUERY
SETTING ASSRESS
OK 🗘